

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. /MMML/WTP office/3/2026-2027

Dated: 20/5/2026

It is certified that an inspection team headed by **Mr. P. S. Patil Hydraulic Engineer (WATER SUPPLY)** (Name of Officers with designation) from **Drinking Water Supply Department of Malkapur Nagarpanchayat**. PHED Inspected the **KCT's Krishna School, Karad**. (Name & Address of the school) on **08/05/2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no **1411** dated **13/05/2026** of **District Public Health Laboratory (PHED Lab)** certified that the **KCT's Krishna School, Karad**. (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **5 years**.



Signature with Seal :

Name : **Mr. P.S. Patil**

Designation : **Hydraulic Engineer (WATER SUPPLY)**

Name & Address of the Office/Department : **Drinking Water Supply Department of Malkapur Nagarpanchayat.**


जल अभियंता
पाणी पुरवठा विभाग
मलकापूर नगरपालिका,
जि. सातारा

To,
KCT's Krishna School, Karad.
(Name & Address of the Institution)

Note : The certificate is to be issued by authorized officer/PHED lab/local bodies.

State / Regional / District / Public Health Laboratory Satara

सा.जि.प.मु./३९३/९९/१०००

E-mail-ID :

Phone No. :

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection :- 7/5/26 Date of Receipt :- 7/5/26 Date of Examination :- 7/5/26

(All the Analytical Result are in mg./Litre except pH, Turbidity)

| Sr.No. | TEST PARAMETER | (1) | (2) | (3) | BIS Specification 10500 : 2012 Normal Values | |
|--------|--|------------------|-----|------------|--|--------------------|
| | | | | | Desirable Limits | Permissible Limits |
| 1. | Physical Appearance | Clear Colourless | / | | - | - |
| 2. | Odour | agreeable | | Agreeable | Agreeable | |
| 3. | Turbidity (as N.T.U.) | 0.43 | | 1.0 | 5.0 | |
| 4. | pH Value | 6.5 | | 6.5 to 8.5 | No relaxation | |
| 5. | Chlorides (as Cl) | 6 | | 250 | 1000 | |
| 6. | Nitrates (as NO ₃) | - | | 45 | No relaxation | |
| 7. | Total Hardness (as CaCO ₃) | 12 | | 200 | 600 | |
| 8. | Alkalinity (as CaCO ₃) | 10 | | 200 | 600 | |
| 9. | Total Dissolved Solids | 33 | | 500 | 2000 | |
| 10. | Iron (as Fe) | - | | 0.3 | No relaxation | |
| 11. | Fluoride (as F) | - | | 1.0 | 1.5 | |
| 12. | Other Tests (if any) | | | | | |
| 13. | | | | | | |
| 14. | | | | | | |
| 15. | | | | | | |
| 16. | | | | | | |
| 17. | | | | | | |
| 18. | | | | | | |
| 19. | | | | | | |
| 20. | | | | | | |

This report is restricted only for the Sample/s is Submitted to this Laboratory.

This Sample/s is / are not Collected by this Laboratory.

(P.T.O.)

REMARKS

A) Sample No. (s) 1 is/are potable / chemically fit for drinking purpose on the basis of analysed Parameters only.

✓ However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No.(s) _____ Contains _____

✗ However, If there is no any other alternate source available nearby then this/these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No.(s) _____ Contains _____

✗ Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed paramtors only.

HEALTH SERVICES

No. 1411

Date: 13/5/2026

Forwarded With Compliments To : Principal,
Krishna Charitable Trust's
Krishna School, Karad.

With reference to letter No. : 1419 , Dated :- 7/5/26

Fees Rs. : 600/-

Receipt No. and Date : 7/5/26


Junior Scientific Officer,
for **District Public Health Laboratory**
Old Civil. Satara